PYRENE FIRE SECURITY MAN.
16 Mazenod Road, Unit #6
Winnipeg, Manitoba
R2J 4H2
Phone: (204) 783-0470
Fax: (204) 783-1130

Emergency Lighting Systems Annual Inspection Report

Customer Number: _____
Report Number: _____
Date: _____
System Manufacturer: _____

Building Name: _____
Address: _____
_____
Building: _____

_____ _____
Name Signature
Printed Name and Signature of Primary or Supervising Technician Conducting the Test.

Legend: ☑ **Yes** Tested Correctly ☑ **No** Did not test correctly (see remarks) ☑ **N/A** Not applicable. Function or feature not provided on this emergency lighting system.

1. Pilot lights are functioning and not obviously damaged or obstructed. ☐ Yes ☐ No ☐ N/A
2. Terminal connections are clean, free of corrosion and lubricated. ☐ Yes ☐ No ☐ N/A
3. Terminal clamps are clean and tight as per manufacturer's specs. ☐ Yes ☐ No ☐ N/A
4. Battery surface is clean and dry. ☐ Yes ☐ No ☐ N/A
5. Systems have been tested to ensure that the emergency lights will function upon failure of the primary power supply. ☐ Yes ☐ No ☐ N/A
6. Systems provide emergency lighting for a duration equal to the design criterion under a simulated power failure condition. ☐ Yes ☐ No ☐ N/A
7. After completion of the duration test, charging conditions for voltage and current have been tested to ensure the charging system is functioning in accordance with the manufacturer's specifications. ☐ Yes ☐ No ☐ N/A

Remarks

Sample