PYRENE FIRE SECURITY MAN.
16 Mazenod Road, Unit #6
Winnipeg, Manitoba
R2J 4H2
Phone: (204) 783-0470
Fax: (204) 783-1130

Fire Hydrant Inspection Report

Customer Number: _____
Report Number: _____
Date: _____

Building Name: _____
Address: _____
_____
Building: _____

General Information

A. Hydrant number _____ of _____
B. Hydrant location: _____
C. Make of hydrant: _____
D. Road box location: _____

Technician's Checklist

A. Was there any accumulation of water in the barrel since the last inspection?	☐ Yes ☐ No	G. Was the hydrant properly drained this inspection?	☐ Yes ☐ No ☐ N/A
B. Was the hydrant flushed with the main valve and any outlet valves fully opened this inspection?	☐ Yes ☐ No	H. Were all stems, caps, plugs, and threads lubricated at the time of inspection?	☐ Yes ☐ No
C. Is the fire hydrant readily accessible and unobstructed?	☐ Yes ☐ No	I. Are all hydrant caps in place?	☐ Yes ☐ No
D. Is the hydrant equipped with an automatic drain?	☐ Yes ☐ No	J. Are all hydrant caps free of any wear?	☐ Yes ☐ No
E. Does the automatic drain operate?	☐ Yes ☐ No ☐ N/A	K. Are all hydrant caps free of any rust?	☐ Yes ☐ No
F. Does the hydrant need to be drained manually?	☐ Yes ☐ No	L. Were all hydrant caps easily removed?	☐ Yes ☐ No

Remarks

_____ _____
Name Signature
Printed Name and Signature of Technician Conducting the Inspection.

Sample