



**PYRENE FIRE SECURITY MAN.**

16 Mazenod Road, Unit #6  
Winnipeg, Manitoba  
R2J 4H2  
Phone: (204) 783-0470  
Fax: (204) 783-1130

# Fire Pump Test Report

Customer Number: \_\_\_\_\_  
Report Number: \_\_\_\_\_  
Date: \_\_\_\_\_

Building Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
Building: \_\_\_\_\_

## General

- A. Fire pump location: \_\_\_\_\_
- B. Type of fire pump: \_\_\_\_\_
- C. Make of fire pump: \_\_\_\_\_
- D. Fire pump serial number: \_\_\_\_\_
- E. Does the fire pump service a standpipe system?  Yes  No  N/A
- F. Does the fire pump service a sprinkler system?  Yes  No  N/A
- G. Is the fire pump ULC listed?  Yes  No
- H. Is emergency power provided for the fire pump?  Yes  No  N/A
- I. Is there a test header available?  Yes  No
- J. Test header location (if applicable): \_\_\_\_\_
- K. Is there a flow meter available?  Yes  No
- Local fire alarm panel: \_\_\_\_\_
- Monitoring station: \_\_\_\_\_
- Phone Number: \_\_\_\_\_
- Location of fire alarm panel: \_\_\_\_\_
- System Number: \_\_\_\_\_
- Passcode: \_\_\_\_\_

## Fire Pump

- A. Rating of Fire Pump: \_\_\_\_\_ USGPM @ \_\_\_\_\_ PSI @ \_\_\_\_\_ RPM
- B. Head in Feet: \_\_\_\_\_
- C. Driver horse power: \_\_\_\_\_
- D. Is the fire pump automatic?  Yes  No  N/A
- E. Is the fire pump semi-automatic?  Yes  No  N/A
- F. Automatic Start at: \_\_\_\_\_ PSI
- G. Automatic Stop at: \_\_\_\_\_ PSI
- H. Timer-Set at:  N/A \_\_\_\_\_ Min.

## Fire Pump Controller

- A. Controller Manufacturer: \_\_\_\_\_
- B. Controller Serial #: \_\_\_\_\_
- C. Is the controller ULC Listed:  Yes  No

## Jockey Pump

- A. Is there a jockey pump on the system?  Yes  No
- B. Is the jockey pump operational?  Yes  No  N/A
- C. Are the jockey pump control valves open?  Yes  No  N/A
- D. Is the jockey pump power on?  Yes  No  N/A
- E. Is the jockey pump set on auto?  Yes  No  N/A
- F. Automatic start at: \_\_\_\_\_ PSI
- G. Automatic stop at: \_\_\_\_\_ PSI

## Technician's Checklist

- A. Were all control valves checked for proper position and operation?  Yes  No  N/A
- B. Are all control valves equipped with tamper switches?  Yes  No  N/A
- C. Are control valves that are not equipped with tamper switches, locked or sealed in the open position?  Yes  No  N/A
- D. Is the relief valve pressure properly adjusted?  Yes  No  N/A
- E. Are water gauges in satisfactory condition?  Yes  No
- F. Does the fire pump running signal the local fire alarm panel, and is this operational?  Yes  No  N/A
- G. Does the fire pump loss of power signal the local fire alarm panel, and is this operational?  Yes  No  N/A
- H. Does the fire pump phase reversal signal the local fire alarm panel, and is this operational?  Yes  No  N/A

